

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201862
Address: 1812 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, July 21, 2021

Corrective Action Required:

1	Misc	-Resolve outstanding inspection fee(s) before final c of o -Submit as graded plot plan for review and approval -lawn irrigation permit -GFCI protection on dishwasher receptacle -splash blocks -gutters and downspouts -secure ac electrical whip within 12" of disconnect and secure whip up off grade -stairs at rear sliding door
---	------	--

Comments: