



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20200773	Date:	July 22, 2021
Project Title:	LSMC Hybrid OR Addition	Applicant:	
Location:			
2100 SE BLUE PKWY, LEES SUMMIT, MO 64063		JAYHAWK FIRE SPRINKLER CO INC	
Type of Work:		12030 S HEDGE LANE TERRACE	
Occupancy Group:	I-2	OLATHE, KS 66061	
Description:	LSMC Hybrid O.R. Addition		
Construction Type:	Type IB	Primary:	(913) 422-3770
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. Update your records showing NFPA 13 2016 Edition

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.