

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210049  
Address: 3018 NW THOREAU PL, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, July 22, 2021

Corrective Action Required:

2	Misc	-Strap header and nail siding of dining CSPF walls per detail -Seal return air space at top plate of front bedroom -Loft windows larger than 9 sq. ft and located less than 18" above floor are required to be tempered glass
---	------	---

**\*\*OK TO INSULATE**

**Comments:**