

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204576
Address: 1721 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Khanh Nguyen	Failed	Thursday, July 22, 2021

Corrective Action Required:

1	Misc	-Install a #4 cu bonding jumper from the grounding bus bar, where the GEC is connected to, to the service grounded bus bar -Can only have one conductor at grounding clamp. Install a separate bonding clamp for the gas bonding conductor
---	------	---

Comments: