

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204576  
Address: 1721 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:   | Outcome: | Date:                   |
|---------------------------------------------|--------------|----------|-------------------------|
| <b>Gas Service Inspection - Residential</b> | Khanh Nguyen | Failed   | Thursday, July 22, 2021 |

Corrective Action Required:

|   |      |                                           |
|---|------|-------------------------------------------|
| 1 | Misc | -Provide min ten psi pressure for testing |
|---|------|-------------------------------------------|

**Comments:**