



PLAN REVIEW CONDITIONS

July 22, 2021

JOE STEWART
125 HIGHLAND PARK AVE
EXCELSIOR SPRINGS, MO 64024

Permit No: PRCOM20213799
Project Title: STRETCHZONE
Project Address: 940 NW PRYOR RD, Unit:B, LEES SUMMIT, MO 64081
Parcel Number: 51800043700000000
Location: STREETS OF WEST PRYOR LOTS 1-14 & TRACTS A-D: LOT 8 (EX TH PT LOT 8 DAF: ALL TH SPACE BETWEEN NAVD8 DEG 27 MIN 16 MIN W 41.99' TO TRU POB TH S 87 DEG 32 MIN 44 SEC E 27.69' TH N 02 DEG 27 MIN 16 SEC E E 29.33' TH S 02 DEG 27 MIN 16 SEC W 36' TH N 87 DEG 32 MIN 44 SEC W 2' TH S 02 DEG 27 MIN 16 SEC W W 4' TH S 02 DEG 27 MIN 16 SEC W 22.67' TH S 87 DEG 32 MIN 44 SEC E 4.67' TH S 02 DEG 16 MIN 27 SEC
Type of Work: NEW TENANT FINISH
Occupancy Group:
Description: TENANT FINISH FOR STRETCHING CLINIC

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. (Action Required)
Any modifications to the fire alarm system, provide PE stamped electronic shop drawings to mike.weissenbach@cityofls.net

2. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued

for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

(Action Required)

Any modifications to the fire sprinkler system, provide PE stamped electronic shop drawings to mike.weissenbach@cityofls.net

3. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

4. 2018 IFC 906.5- Conspicuous location. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel.

(Action Required)

Provide one 2A10BC Fire Extinguisher.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.