

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20210729  
Address: 2159 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Residential</b>	Michael Harkins	Failed	Friday, July 23, 2021

Corrective Action Required:

1	Miscellaneous Correction	: GARAGE PFH PORTAL FRAMING ONLY :
---	--------------------------	------------------------------------

FOR A PANEL SPLICE PANEL EDGES SHALL BE BLOCKED AND OCCUR WITHIN 24" OF MID-HEIGHT.  
ONE ROW OF SHEATING TO FRAMING NAILING IS REQUIRED( 3" GRID). IF 2X4 BLOCKING IS USED, THE 2X4s MUST BE NAILED TOGETHER WITH (3) 16D SINKERS PER PLAN DETAIL 1 SHEET S4.0

**Comments:**