

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212956
Address: 3101 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Friday, July 23, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED
---	------	-------------------

-FOOTING POURED WITHOUT INSPECTION - STOP WORK ISSUED
-POST ADDRESS

Comments: