CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20202240

Address: 2353 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

Inspected On: Friday, July 23, 2021

Inspected By: Robb Popp

Expiration Date: 7/30/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - Robb Popp Temporary C of O Friday, July 23,

Codes Residential 2021

Corrective Action Required:

1 Misc TCO until 7-30-21

-Ledger connection to structure per code

-Secure raceway at equipment disconnect termination, condensing

unit whip