

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203515

Address: 2608 SW WARD RD, LEES SUMMIT, MO 640822600 SW WARD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Partial	Friday, July 23, 2021

Informational:

1	Misc	Visitors concession/restrooms only - partial approval of plumbing and electrical. Plumbing in concealed chases approved to ceiling level. Electrical conduit in CMU walls approved up to 8 blocks in height
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	THIRD FLOOR	PRESS BOX 3RD FLOOR- STORAGE WALL OK TO ONE SIDE W1-302 NORTH EXTERIOR WALL OK TO COVER W1-S3 ok to cover except stair wall at door , install exit light over door.
---	-------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: