

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212857

Address: 3807 SW WALSH DR, LEES SUMMIT, MO 640823803 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Robb Popp	Failed	Friday, July 23, 2021

Corrective Action Required:

1	Misc	7-23-21
		-Restore silt fence and provide gravel filter at drive before any further inspections
		-Interior drain tile is required to extend to furthest corner from sump pump or around perimeter and slope toward sump pump

Comments: