

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211980  
Address: 512 SE DAVID RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Residential</b>	Robb Popp	Failed	Friday, July 23, 2021

Corrective Action Required:

1	Misc	-Post address before any further inspections -Solid block sheathing breaks and nail 3" OC per detail -Nail top plate to header with (2) rows 16d sinkers 3" OC per detail -Do not cover
---	------	--

**Comments:**