

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203754
Address: 1504 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Plot Plan Inspection	Patrick Schonfeldt	Failed	Friday, July 23, 2021

Corrective Action Required:

1	Misc	-REMOVE ROCKS AND DEBRIS FROM SWALE, MAINTAIN VEGETATION AT SWALE, COMPLETE SOD TO SWALE
---	------	--

Comments: