### **S** LEE'S SUMMIT MISSOURI

#### **DEVELOPMENT SERVICES**

#### **Residential Plan Review**

July 27, 2021

SAB CONSTRUCTION LLC PO BOX 942 LEES SUMMIT, MO 64063 (816) 524-3855

| Permit No:       | PRRES20213528  |
|------------------|--|
| Plan Name:       |  |
| Project Address: | 2361 SW OLD PORT RD, LEES SUMMIT, MO 64082                   |
| Parcel Number:   | 6922005100000000   |
| Location:        | EAGLE CREEK SIXTEENTH PLAT LOTS 708-747 INC & TRACT RLOT 728 |
| Type of Work:    | NEW SINGLE FAMILY  |
| Occupancy Group: | RESIDENTIAL, ONE- AND TWO-FAMILY                             |
| Description:     | NEW HOUSE - FINISHED/UNFINISHED BASEMENT - COVERED DECK      |

#### **Revisions Required**

# The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

| Residential Plan Review | Reviewed By: Kim Brennan | Approved |
|-------------------------|--------------------------|----------|
| Plot Plan Review        | Reviewed By: Kim Brennan | Rejected |

1. Property boundary distances and bearings, as shown on the recorded plat, must be provided on the plot plan.

Distance along the right and rear lot lines are not consistent with the recorded plat

2. The right-of-way with dimensions must be provided on the plot plan.

Please show SW Ladderback Rd and its ROW dimension

3. Existing and finish elevations at all property corners must be provided on the plot plan.

Missing on the rear left side

4. Basement egress location(s) and elevation of the lowest adjacent grade must be provided on the plot plan.

Please provide elevation for walkout/walkup.

5. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.

**Planning Review RES** 

**Reviewed By:** 

Not Required

## The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

| Residential Area:                  |    |                     |      |  |
|------------------------------------|----|---------------------|------|--|
| Residential, Living Area           |    | 1800                |      |  |
| Residential, Un-Finished basements |    | 660                 |      |  |
| Residential, Finished basements    |    | 1100                |      |  |
| Residential, Decks                 |    | 172                 |      |  |
| Residential, garage                |    | 706                 |      |  |
|                                    |    |                     |      |  |
| Roofing Material                   |    | Number of Bathrooms | 3.5  |  |
| Number of Bedrooms                 | 4  | Number of Stories   | 1    |  |
| Number of Living Units             | 1  | Total Living Area   | 2900 |  |
| Sewer Connection Fee               | 16 |                     |      |  |