

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20202286  
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Hydrostatic Test</b>	John DiMauro	Passed	Tuesday, July 27, 2021

Informational:  
1 Misc On Monday, 7-26-2021, Red Ford Excavating performed a Hydrostatic test on the 8" water line that passed the hold time for pressure. Contractor Chlorinated line as well.

**Comments:**