

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204988  
Address: 310 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Not Ready	Tuesday, July 27, 2021

Corrective Action Required:

1	Miscellaneous Correction	PROVIDE FINAL GRADE Garage door shall be self closing & self latching Sump shall discharge 36" from foundation PAY FEES PROVIDE BACKFLOW CERTIFICATION SIDEWALK INSPECTION STILL PENDING PROVIDE SOD & SPLASH BLOCKS Provide 6" clearance wood siding to finish grade
---	-----------------------------	--

**Comments:**