

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20204988
Address: 310 NW AMBERSHAM DR, LEES SUMMIT, MO 64081
Inspected On: Tuesday, July 27, 2021
Inspected By: Michael Harkins
Expiration Date: 08/26/2021

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|-----------------|------------------|---------------------------|
| Occupancy Inspection - Codes Residential | Michael Harkins | Temporary C of O | Tuesday, July 27, 2021 |

Corrective Action Required:

| | | |
|---|-----------------------------|---|
| 1 | Miscellaneous Correction | PROVIDE FINAL GRADE Sump shall discharge 36" from foundation PAY FEES PROVIDE BACKFLOW CERTIFICATION SIDEWALK INSPECTION STILL PENDING PROVIDE SOD & SPLASH BLOCKS Provide 6" clearance wood siding to finish grade |
|---|-----------------------------|---|