

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210293
Address: 3022 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Tuesday, July 27, 2021

Corrective Action Required:

1	Misc	garage Portal ok- covered deck rafters and post framing covered , no inspection. Post visible address, address erosion control. cut over grown vegetation to max 10" in height , contain all trash and debris.
		Provide report from truss manufacture on screws holding down truss on covered deck. Screws are through the siding and not at the correct height and location through both tope plates.

Comments: