

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20204527
Address: 1519 SW SUGAR TREE DR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, July 27, 2021
Inspected By: Patrick Schonfeldt
Expiration Date: 8/13/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Tuesday, July 27, 2021

Corrective Action Required:

1	Misc	-Install extension at sump pump discharge -set sewer tracer to box and set box at grade -Ensure 6" of fall from foundation within first 10' around perimeter of foundation, foundation has negative slope on east side of house and along retaining wall
---	------	--

****OK FOR TCO - TCO EXPIRES 8/13/21****