

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210049
Address: 3018 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, July 28, 2021

Corrective Action Required:

1	Misc	-nail siding of dining CSPF walls per detail -Loft windows larger than 9 sq. ft and located less than 18" above floor are required to be tempered glass
---	------	--

****OK TO INSULATE**

Comments: