

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210595
Address: 4409 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, July 28, 2021

Corrective Action Required:

1	Misc	-seal penetrations in fireblock between top plate basement south wall -LIB bracing all locations per plans -see garage -Complete plumbing that was removed for correction of dbl floor joists at kitchen island
---	------	---

Comments: