

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210699
Address: 3109 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mark Harding	Failed	Wednesday, July 28, 2021

Corrective Action Required:

1	Misc	-GAS PRESSURE GAUGE AT 0 PSI, MUST MAINTAIN 10 PSI FOR TEST
		no gauge 2nd inspection

Comments: