

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210050
Address: 338 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Wednesday, July 28, 2021

Corrective Action Required:

1	Misc	PROVIDE PROTECTION TO AVOID DAMAGE TO ELECTRICAL EQUIPMENT AT SERVICE PANEL DWV ABOVE (E3405.3 2018 IRC)
---	------	--

Comments: