

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204555
Address: 1817 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|--------------------------|
| Occupancy Inspection - Codes Residential | Robb Popp | Failed | Wednesday, July 28, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Pay all fees due before final occupancy -Clean mud from street in front of property -Mising cover plate at front entry -Install missing fixture above stairs -Secure handrail at stairs -Adjust garage entry door to close and latch -Label all dedicated non GFCI outlets in garage and basement |
|---|------|--|

Comments: