

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204976
Address: 2910 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Nick Lightner	Passed	Wednesday, July 28, 2021

Informational:
1 Misc 7/22/21 13:56 - Sidewalk is the correct depth, correct depth of rock has been installed, 5ft off the back of the curb, and is carrying the correct % throughout.

Informational:
2 Misc 7/28/21 14:40 - Sidewalk is carrying the correct % throughout and has been white cured.

Comments: