

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20202637  
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection</b>	Tom Taylor	Passed	Thursday, July 15, 2021

Informational:

1 Misc

On Tuesday 7-13-2021. She Diggs it installed the 16" 'T' and Butter fly Valve for the main connection to the school. The restraint for the 'T' was poured on Wednesday.

On Wednesday, 7-27-2021. She Diggs it Performed a Hydrostatic Presure test on the domestic water line that passed city standards and held 150lbs of pressure for 2 Hrs.

**Comments:**