

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212723
Address: 4713 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Thursday, July 29, 2021

Informational:

1 Misc

****UNDERSLAB PLUMBING OK**
****THE FOOTING APPROVED BY YOUR ENGINEER BUT A COLUMN PAD IS MISSING. SCHEDULE FOR A FOOTING INSPECTION WHEN READY**
****HAVE THE EROSION CONTROL FIXED FOR THE NEXT FOOTING INSPECTION**

Comments: