

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212066
Address: 4416 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, July 29, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED FOOTING POURED WITHOUT INSPECTION, SUBMIT ENGINEER REPORT WITHIN 48 HOURS OF INSPECTION
---	------	---

Comments: