

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211647  
Address: 250 NW MCNARY CT, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Michael Harkins	Partial	Thursday, July 29, 2021

Corrective Action Required:  
1 THE FOLLOWING AREAS ARE APPROVED - PARTIAL SOUTH END UNDERSLAB FOR ANIMAL HOSPITAL -

**Comments:**