

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202689
Address: 2345 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, July 30, 2021

Corrective Action Required:

2	Miscellaneous Correction	OK to insulate -Identify ufer ground and gas bond at all locations-BOTH ends -Bond gas line before ward flex connection-before range-Terminate in panel and identify as grounding conductor on each end -Provide ledger to house connections and (2) 1/2" through bolts at post to beam connection at deck
---	--------------------------	---

Comments: