

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203307
Address: 1344 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Final - Residential	Khanh Nguyen	Failed	Friday, July 30, 2021

Corrective Action Required:

1	Miscellaneous Correction	-ADDRESS POOL BONDING INSPECTION NOT APPROVED
---	-----------------------------	---

****Alternate method on north side of pool requires single bare 8awg conductor to be placed 18-24" from inside wall of pool, buried 4-6" in depth. Expose this bonding conductor for verification**

Comments: