

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204900
Address: 1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Friday, July 30, 2021

Informational:

1	Misc	: THE FOLLOWING AREAS ARE APPROVED :
		- COOLER WALLS, ELECTRICAL PANEL WALL -

Corrective Action Required:

2	Misc	Seal upward penetrations (fire caulk) Provide mid point support vertical DWV 2" & smaller Boca plates plumbing Provide anchor bolts within 12" of plate break & end of plate Secure wall at cleaning room
---	------	---

Comments: