CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204900 Address: 1460 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | | Inspector: | Outcome: | Date: |
|-----------------------------|-------------------------------------|---|------------------|-----------------------|
| In-wall Inspection | | Michael Harkins | Failed | Friday, July 30, 2021 |
| Informational: | | | | |
| 1 | Misc | : THE FOLLOWING AREAS ARE APPROVED : | | |
| | - COOLER WALLS, ELECTRICAL PANEL WA | | CAL PANEL WALL - | |
| Corrective Action Required: | | | | |
| 2 | Misc | Seal upward penetrations (fire caulk) | | |
| | | Provide mid point support vertical DWV 2" & smaller | | |
| | | Boca plates plumbing | | |
| | | Provide anchor bolts within 12" of plate break & end of plate | | |
| | | Secure wall at cleaning room | | |

Comments: