

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211035
Address: 4412 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, August 02, 2021

Corrective Action Required:

1	Misc	-Address broken truss C6 above front entry at dining room -field fix per engineer letter -Nail exterior sheathing per plans -Full height continuous 6x6 cedar posts at deck per plans-field fix per engineer letter **OK TO INSULATE**
---	------	---

Comments: