

July 19, 2021

**LOGAN
& ASSOCIATES**
Professional Engineers
P.O. Box 1508
Liberty, Missouri 64069


City of Lee's Summit
220 SE Green Street
Lee's Summit, Missouri 64063

Attn: Building Inspections
Re: Cardinal Crest Homes, Pergola Park, Lot 105, 3213 SW Mary Street, Lee's Summit,
Missouri, Permit No. PPRES2021-2068; footing inspection


To whom it may concern:

An inspection was conducted on Monday, July 19, 2021 regarding the above referenced. For reference purposes the house faces north. The basement and garage footing were constructed with the standard 16" wide x 8" thick with (2) 1/2" rebar continuous throughout the footing area. There are (3) pads in the basement and (2) pads in the garage for future concrete columns. The steel reinforcing for the perimeter footings and pads were in place at the time of the inspection. The footing and pads were founded on solid original shaley clay soil. The ground rod was installed. The concrete contractor, Mid States Form, was given permission to place the concrete into the forms. If you have questions, please contact me at my office.

Sincerely,
Logan & Associates, Inc.



Charles R. Logan, PE
President



cc: Cardinal Crest Homes