

July 30, 2021



City of Lee's Summit
220 SE Green Street
Lee's Summit, Missouri 64063

Attn: Building Inspections
Re: Cardinal Crest Homes, Pergola Park, Lot 105, 3213 SW Mary Street, Lee's Summit, Missouri, Permit No. PPRES2021-2068; wall inspection

To whom it may concern:

An inspection was conducted on Friday, July 30, 2021 regarding the above referenced. For reference purposes the house faces north. The 6' foundation walls were constructed 8" thick with vertical and horizontal 1/2" rebars on 24" centers both ways. The 9' tall foundation walls were constructed 8" thick with horizontal 1/2" rebars on 24" center and vertical 1/2" rebars on 12" ± centers. No keyway or hook bars were installed in the perimeter garage. The basement is slab on grade. The steel reinforcing bars were in place in the foundation wall forms. The foundation contractor, Mid States Form, was given permission to place the concrete into the forms. If you have questions, please contact me at my office.

Sincerely,
Logan & Associates, Inc.

A handwritten signature in black ink that reads 'Charles R. Logan'.

Charles R. Logan, PE
President



cc: Cardinal Crest Homes