## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20211138

Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection		Ronald Paynter	Partial	Tuesday, August 03, 2021
Informational:				
1	Misc	Patrick's crew from Redford Construction core cut existing manhole 35-572. They also set manhole 5-A1, along with 220 feet of sanitary pipe and service laterals for lots 134 and 138. RP 7-13-21		
Informational:				
2	Misc	Patrick's crew set manholes 5-A2 and 5-A3. They also laid over 200 feet of sanitary pipe. RP 7-14-21		
Informational:				
3	Misc	Patrick's crew set manholes 5-A2 and 5-A3. They also laid over 200 feet of sanitary pipe. RP 7-14-21		
Informational:				
4	Misc	Patrick's crew set manhole 5-B. They also laid 250 feet of sanitary pipe. RP 7-15-21		
Informational:				
5	Misc	Patrick's crew set service laterals for lots 153, 154 and 137. They also laid 100 feet of sanitary pipe for line 5-C. RP 7-16-21		
Informational:				
6	Misc	also working on the servi	d and the crew was working ce lines for 152 and 151. The e previous service lines tha	ey were doing some
Informational:				
7	Misc	Patrick's crew core cut in	existing manhole 35-573. T	hey also laid 50 feet of

sanitary pipe and service laterals for lots 144 and 145. RP 7-20-21

Informational:

8 Misc Patrick's crew set MH 5D-1 and service laterals for lots 145, 146, 143, 142 and

147. Jarrod's crew core cut existing MH 35-574 and laid 50 feet of sanitary

pipe. RP 7-21-21

Informational:

9 Misc Patrick's crew poured inverts for 5-D1, 5-C1, 5-C2, 5-A1, 5-A2, 5-A3, 5-B1.

They started stacking MH's. Jarrod's crew laid 150 feet of sanitary pipe. They

set MH 6-D1 and service laterals for lots 167, 168, 169 and 170. RP 7-22-21

Informational:

10 Misc Cones and barrel sections were delivered today. Jarrod's crew laid service

laterals for lots 171, 172 and 173. Both crews poured trench checks for all service laterals on lines 6B, 5B, 5C, 5D and 5A. They stacked MH's and back

filled the rest of the day. RP 7-23-21

Informational:

11 Misc Jarrod's crew laid 225 feet of sanitary pipe out of MH 5B-1 to MH 6A-1.

Patrick's crew laid service laterals for lots 160, 161, 162, 163, 209 and 210. RP

7-26-21

Informational:

12 Misc Patrick's crew laid 200 feet of sanitary pipe and MH 6C-1. They also laid

service laterals for lots 178, 179, 208 and 207. Jarrod's crew also laid 200 feet of sanitary pipe and MH 6A-3. They also laid service laterals for lots 164, 165,

166, 174, 175, 176 and 177. RP 7-27-21

Informational:

13 Misc Patrick's crew laid 150 feet of sanitary pipe and set MH 6C-2. They also laid

service laterals for lots 206, 205 and 180. Jarrod's crew has been back filling

and doing compaction testing with KC Testing. RP 7-28-21

Informational:

14 Misc Both crews worked on back filling and KC Testing was on site doing

compaction testing. Patrick's crew also laid 50 feet of sanitary pipe out of MH

6C-2. RP 7-29-21

Informational:

15 Misc Patrick's crew laid 250 feet of sanitary pipe and set MH 6C- 3. Jarrod's crew

laid service laterals for lots 204, 203 and 202. RP 7-30-21

Informational:

16 Misc Patrick's crew laid 270 feet of sanitary pipe and set MH's 6C-4 and 6C-5.

Jarrod's crew laid 150 feet of sanitary pipe and set MH 6D-1. RP 8-2-21

Informational:

17 Misc Cityview training with Tom Taylor. RP 8-3-21

**Comments:**