



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20213195, Public Works Right of Way Permit
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Partial	Tuesday, August 03, 2021

Corrective Action Required

1	Misc	Site Visit - A crew was onsite boring in the easement. I let them know to stay 36" under the road or more in-depth if they are crossing. Currently they are running in an U/E. This is a new developed area without houses yet.
---	------	---

Comments: