

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202689  
Address: 2345 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:   | Outcome: | Date:                    |
|---|--------------|----------|--------------------------|
| <b>All Rough Inspection - Residential</b> | Khanh Nguyen | Failed   | Tuesday, August 03, 2021 |

Corrective Action Required:

|   |                          |  |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | OK to rock<br><br>-Provide ledger to house connections and (2) 1/2" through bolts at post to beam connection at deck |
|---|--------------------------|--|

**Comments:**