

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201709
Address: 2020 SW HOOK RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	John DiMauro	Passed	Tuesday, August 03, 2021

Informational:
1 Misc On Monday, 7-26-2021. Red Ford Excavating Completed a Hydrostatic Pressure test and passed the 2 hr 150 lbs pressure time limit, passing test.

Comments: