CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204535

Address: 2029 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Driveway Inspection Ronald Paynter Partial Tuesday, August 03,

2021

Informational:

1 Misc Forms were placed and aggregate was present and compacted. RP 8-3-21

Comments: