

ANALYTICAL REPORT

May 29, 2021

Work Order: 1EE2758

Page 1 of 3

Report To
Joe Starlin City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 05/28/2021 1:26PM Collector: Client Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Breit Construction LLC

Project Number: Down Town Apartments

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1EE2758-01	A			Matrix:Drink Wtr		Collected: 05/28/21 12:15	
Total Coliforms	<1.0 MPN/100ml	1.0	1EE1445	9223B-QT	CLJ	05/28/21 17:00	
E. Coli	<1.0 MPN/100ml	1.0	1EE1445	9223B-QT	CLJ	05/28/21 17:00	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.
220 SE Green Str
Lees Summit, MO 64063

May 29, 2021
Page 2 of 3

Work Order: 1EE2758

Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2022
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2021
MO-KC	Missouri Department of Natural Resources	140	04/30/2021
SIA1X	Iowa Department of Natural Resources	95	02/01/2021

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson
Project Manager

