

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211433
Address: 107 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, August 04, 2021

Corrective Action Required:

1	Misc	No city approved plans on site Garage anchor bolts shall Land in middle 1/3 of width of plate Covered patio provide hangers & H2.5a per plan Front porch trusses not set at this time
---	------	--

Comments: