

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210948
Address: 306 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Wednesday, August 04, 2021

Informational:	
1 Misc	GARAGE PFH PORTAL FRAME OK TO COVER FRONT PORCH OK TO COVER COVERED DECK OK TO COVER : ONLY ABOVE ITEMS INSPECTED :

Corrective Action Required:	
2 Miscellaneous Correction	Provide LIB bed #2 closet per plan (provide 2 nails top & bottom plate) Fire block (insulate) beam pockets Seal Upward penetrations above service panel Install tubs Nail exterior sheathing per code GAS SERVICE FAILED AGAIN NO PRESSURE

Comments: