

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201877
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit	John Jackson	Partial	Wednesday, August 04, 2021

Informational:

1 Misc

Possible that storm drain may require maintenance, Steve Robbins received a call from the resident at 4828 NE Jamestown Rd. The existing field inlet needs to be clean out & build a protection around it. The culvert that discharges into the retention basin that is in the rear of property needs to be clean out. See pics for the day.

Comments: