

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203873
Address: 1916 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Nick Lightner	Passed	Wednesday, August 04, 2021

Informational:

1	Misc	7/27/21 14:45 - Crew has the correct depth of rock and forms are the correct depth. 5ft off the back of the curb and is carrying the correct % throughout.
---	------	--

Informational:

2	Misc	8/4/21 13:55 - Sidewalk is installed correct with the correct % throughout.
---	------	---

Comments: