



LEE'S SUMMIT GRID: 0901

94°21'52"W 38°57'2"N NAD83

Maximo WO #: 22583166

THE ROUTE OF THE GAS SERVICE MUST BE BROUGHT TO GRADE AND CLEARED OF BUILDING MATERIAL BY THE CUSTOMER PRIOR TO INSTALLATION.

GRANULAR BACKFILL, IF REQUIRED, IS TO BE PROVIDED BY THE CUSTOMER. IN WHICH CASE, SPIRE WILL NOT BE RESPONSIBLE FOR THE DISPOSAL OF EXCESS SPOIL FROM THE DITCH.

SPIRE TO ONLY PATCH THAT PAVEMENT REMOVED FOR THE INSTALLATION OF THE GAS SERVICE.

PIPE SYSTEM

PRESSURE SYS - C-013

MINOP -

MOP - 25 PSIG

MAOP - 25 PSIG

DESIGNED MAOP - 60 PSIG

TEST PRESSURE - 100 PSIG

CUSTOMER APPROVAL SIGNATURE:

