

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210347
Address: 1221 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, August 05, 2021

Corrective Action Required:

1	Misc	-Secure fireplace to framing -Fasten together the 5x joist under fireplace -Repair damaged cable at stair wall. Move the wiring to inside stud space
---	------	--

****OK TO INSULATE**

Comments: