

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204442  
Address: 2009 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Thursday, August 05, 2021

Corrective Action Required:

1	Miscellaneous Correction	Pay outstanding fees Sidewalk inspection still pending Provide final grade, sod & splash blocks Lower water meter lid to grade Submit back flow certification Provide access to test GFCI receptacle jacuzzi tub Install hood at cooktop Repair broken window dining room Complete fireplace deck A 4" sphere shall not pass through deck spindles Provide through bolts deck beam to post connection Complete treads deck stairway Sump discharge 36" from foundation Seal exterior penetrations irrigation at garage
---	--------------------------	---

Comments: