

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200719
Address: 342 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Ronald Paynter	Passed	Thursday, August 05, 2021

Informational:	
1 Misc	Seal O Matic laid 98 tons of APWA Type 2 R asphalt for the parking lot base.
Informational:	
2 Misc	Seal-O-Matic laid 55 tons of APWA Type 3 R asphalt for the surface of the parking lot. KC Testing was on site for compaction testing. RP 6-2-21
Informational:	
3 Misc	Parking lot has NO drainage issues. RP 8-5-21

Comments: